

Why are combination smoke/carbon monoxide alarms not listed in the carbon monoxide section of the California State Fire Marshal (CSFM) Building Materials Listing (BML) Program?

Combination smoke/carbon monoxide detection devices are listed in the smoke alarm section of the California State Fire Marshal (CSFM) Building Materials Listing (BML) Program.